

# **FMTD722-M** Forbes Marshall Thermodynamic Trap

# Description

The Forbes Marshall Thermodynamic Trap, FMTD722-M, is a maintainable high pressure thermodynamic steam trap with an integral strainer and a replaceable seat for ease of maintenance. It has low capacity and is specifically designed for superheated applications up to 250 bar g.

# **Sizes and Pipeline Connections**

 $\mathsf{DN15}$  /  $\mathsf{DN20}$  and  $\mathsf{DN25}$  butt weld ends to suit SCH160 pipe.

DN15 and DN20 socket weldable ends to ASME (ANSI). B 16.11 Class 6000.

Available with IBR certificate.

**Note :** Available with ANSI 600 and ANSI 1500 flanges on request

# **Limiting Conditions**

Note : if the product is used at pressure above 170 bar

barg we recommend regular inspection of the seat.

Body design conditions	PN250		
PMA Maximum allowable pressure	250 barg @300°C		
TMA Maximum allowable temperature	550°C @ 80 barg		
Minimum allowable temperature	-29°C		
PMO Maximum operating pressure	220 barg@374°C		
TMO Maximum operating Temperature	550°C @ 80 barg		
Minimum operating temperature	0°C		
PMOB Maximum operating back pressure should not exceed 50%			
of upstream pressure			
Minimum operating differential	8 barg		
temperature			
Designed for a maximum cold hydraulic	375 barg		
test pressure			

WITHDRAWAL DISTANCE				
	Size	DN 15	DN20	DN25
	А	105	105	105
	В	80	80	80
	С	80	80	80
	D	90	90	90
	E	55	55	55
	F	55	55	55
	Weight	8 Kg	8 Kg	8 Kg
ш				
WITHDRAWAL DISTANCE				



Material			
No.	Part	Material	Standard
1	Body	Alloy Steel	ASTM A182F 22
2	Top Cover	Alloy Steel	ASTM A182 F 22
3	Disc	Steel	AISI D2
4	Seat	Steel	AISI D2
5	Top Cover Gasket	Spirally wound	(ASME B16-20)
		SS with exfoliated	
		graphite filler	
6	Inner seat Gasket	SS with exfoliated	
		graphite filler	
7	Cover Nuts	Steel	ASTM A194 Gr. 4
8	Cover Studs	Steel	ASTM A193 Gr. B.16
9	Bottom	SS with exfoliated	(ASME B16-20)
	Cover Gasket	graphite filler	
10	Strainer Screen	Stainless Steel	BS 970 304 515/
	Assembly		sintered stainless
			(ASTM A276-304)
11	Bottom Cover	Alloy Steel	ASTM A182 F22
12	Ferrule	Stainless Steel	

# How to Order

Example : 1 No. Forbes Marshall Thermodynamic Trap, FMTD722-M, with maintainable seat, butt weld ends to suit schedule 160 pipe.







# **Spare Parts**

The spares available are shown in solid outline. Parts drawn in broken line are not supplied as spares.

#### **Available spares**

Set of cover studs and nuts	8 and 7 (pack of 8)	
Strainer screen and gasket	10, 9	
Set of gaskets	5 (2 nos), 6, 9	
	(Pack of 3)	
Set of internals	3, 5 (2 Nos.),	
	6, 9, 10, 4+12	

#### Recommended tightening torques

ltem	Part	Or mm	Nm
10	Spool	22 A/F	25-35
8	Stud	M 16	85-90
7	Nut	23 A/F M16	160-180

# Safety Information, Installation and Maintenance

For full details see the installation and maintenance instruction supplied with the product.

# **Installation Note**

The FMTD722-M is designed for installation with the nameplate on top, in a horizontal pipeline. For ease of maintenance, consideration should be given to fitting isolation valves upstream and downstream of the steam trap.

After 24 hours in service the cover nuts should be checked for tightness.





www.forbesmarshall.com

Forbes Marshall Arca

Codel International

**Krohne Marshall** Forbes Vyncke

Forbes Marshall Steam Systems

Forbes Marshall Pvt. Ltd. A: Opp. 106th Milestone, CTS 2220, Mumbai-Pune Road, Kasarwadi, Pune MH 411034 INDIA P: +91(0)20-68138555

F: +91(0)20-68138402

E: ccmidc@forbesmarshall.com

Forbes Marshall International Pte. Ltd. 16A, Tuas Avenue 1, #05-21, JTC Space @Tuas Singapore - 639533 P: +65 6219 3890

#### CIN No: U28996PN1985PTC037806

© All rights reserved. Any reproduction or distribution in part or as a whole without written permission of Forbes Marshall Pvt Ltd, its associate companies or its subsidiaries ("FM Group") is prohibited. Information, designs or specifications in this document are subject to change without notice. Responsibility for suitability, selection,

installation, use, operation or maintenance of the product(s) rests solely with the purchaser and/or user. The contents of this document are presented for informational purposes only. FM Group disclaims liabilities or losses that may be incurred as a consequence of the use of this information.

DOC# FMSS/0824/TIS-FMTD76-M/R4